

Integrity

Design & Test
Services

An Entela, Inc. Company

Certificate of Compliance

The following product was found to comply with the requirement stated below when tested in accordance with the test procedures described in the accompanying test/measurement report. Reference report number 66755.c1.rev.2


Manufacturer: American Power Conversion
9 Executive Park Drive
N. Billerica, MA 01862-1318

Model: SUA1000I & SUA1500I

Requirement: EN 50091-2/IEC 62040-2
IEC 61000-4-2, IEC 61000-4-3,
IEC 61000-4-4, IEC 61000-4-5,
IEC 61000-3-2, IEC 61000-3-3,
IEC 1000-2-2, IEC 61000-4-6
IEC 61000-4-11
CISPR 22, EN55022
Passed when tested as received or Passed with
modification

Applicable
Directive: 89/336/EEC

Approved By:

Michael Koffink Section Manager	
Date	6/2/01

Remarks: *Testing is performed using calibrated equipment traceable to the National Institute of Standards and Technology (NIST).*

This certificate is valid for products tested as described in the accompanying test report. Specific modifications necessary to meet the above requirement, recommended by Integrity Design & Test Services, Inc. are described therein.